

University of MN

Monthly Metrics

May 2024

Energy Management oversees the operation of mechanical, electrical, and civil utilities systems for the Twin Cities campus. This set of monthly metrics provides measurement of the group's three core principles:

- 1) Reliability
- 2) Sustainability
- 3) Cost-effectiveness


RELIABILITY

Unplanned Service Loss Events

	FY18	FY19	FY20	FY21	FY22	FY23	FY24 @ 10 of 12	FY24 Target
CHILLED WATER								
Total	1	0	0	0	0	0	0	
Root-Caused to UMN	1	0	0	0	0	0	0	2
ELECTRIC								
Total	6	10	6	6	9	12	4	
Root-Caused to UMN	2	5	4	2	3	3	3	3
STEAM								
Total	3	6	2	3	1	0	0	
Root-Caused to UMN	2	1	2	3	0	0	0	2
WATER								
Total	1	1	1	1	1	0	0	
Root-Caused to UMN	0	0	1	1	0	0	0	1

This chart shows the number of unplanned utility outages on campus each year. Some outages are out of University control, such as actions of our utility provider or acts of nature. Energy Management sets targets each year for number of outages that are caused by our work.

RELIABILITY




	Apr-23	May-23	Jun-23	Jul-23	Aug-23	Sep-23	Oct-23	Nov-23	Dec-23	Feb-24	Mar-24	Apr-24
Monthly Failures	2.59%	0.00%	0.00%	1.72%	2.59%	0.86%	0.00%	0.86%	0.00%	0.00%	0.00%	0.00%
12-month Average	0.79%	0.79%	0.72%	0.79%	0.93%	0.93%	0.93%	0.93%	0.86%	0.79%	0.72%	0.50%

In the event of a power outage, the campus has a number of emergency generators standing by to power essential systems. Energy Management tests them monthly to ensure they are properly maintained and ready for service.


RELIABILITY

EM maintains nearly 1200 energy meters throughout campus, which are used to collect building energy consumption data. This measure of the metering system’s health shows how many meters are malfunctioning compared to the previous year.



Period:	Jul-23	Aug-23	Sep-23	Oct-23	Nov-23	Dec-23	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24
Meter Read Inventory:	1466	1466	1466	1466	1466	1469	1469	1469	1469	1469	1469	1469
Estimated Readings:	25	23	23	23	18	22	21	24	18	0	0	0
% Monthly Estimates:	1.7%	1.6%	1.6%	1.6%	1.2%	1.5%	1.4%	1.6%	1.2%	0.0%	0.0%	0.0%

RELIABILITY



Steam and condensate meters are more likely to malfunction than other types of utility meters, since they have mechanical parts and operate in extreme environments. Where possible, EM employs additional meters to achieve metering redundancy. This graph shows the percentage of buildings where there is no redundancy for a malfunctioning meter and we are forced to bill using estimated usage.

RELIABILITY


APRIL 2024

TOTAL MONTHLY LABOR HOURS BY CREW AND MAINTENANCE TYPE

	CHILLED WATER	ELECTRIC	EMELEC	EMTECH	STEAM	WATER & SEWER	TOTAL	TOTAL
ADMIN							0	0%
CORRECTIVE	362	432	89	22	532	172	1,608	15%
ISA	43	727	319	10	311	8	1,416	13%
PM-CORRECTIVE	163	126		10		19	317	3%
PREVENTIVE	1,458	1,214		17	2,486	283	5,458	51%
SERVICE	92	49	107	555	2	137	941	9%
STANDING		126		853		4	982	9%
TOTAL	2,118	2,673	514	1,465	3,331	622	10,723	100%


Energy Management crews play a number of different roles in the operation and maintenance of campus utility system.

These charts show the total labor hours worked by each crew for the month and which types of work they performed.




RELIABILITY

Different work happens at different times of the year. This graph shows the ebb and flow of work devoted to each maintenance type over the most recent 12-month period.



RELIABILITY


When operating and maintaining equipment, a good rule of thumb is to have a ratio of preventive labor hours to corrective maintenance hours equal to 2. This indicates that you are taking care of your equipment in a robust way, catching small problems during maintenance before they become big ones that cost more time and money to resolve.



LABOR HRS - CORRECTIVE vs PREVENTIVE

	May-23	Jun-23	Jul-23	Aug-23	Sep-23	Oct-23	Nov-23	Dec-23	Jan-24	Feb-24	Mar-24	Apr-24
Preventive/Corrective	1.9	1.5	1.1	1.0	1.0	1.9	2.0	3.0	3.0	1.9	2.2	2.8
Rolling 12 Average	2.2	2.1	1.9	1.8	1.8	1.8	1.8	1.9	2.0	2.0	1.9	2.0

SUSTAINABILITY



Monthly Emissions (Metric Tons CO₂):

FY	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
Baseline	20,028	19,326	18,127	20,743	27,030	27,098	31,182	30,204	25,248	19,833	16,610	16,701
2020	19,093	18,688	18,009	20,029	24,667	27,357	28,101	26,235	20,485	16,771	14,262	14,630
2021	16,282	16,618	14,999	20,092	20,668	24,682	25,878	32,580	20,714	17,573	16,089	16,639
2022	17,170	17,077	16,062	17,635	21,622	26,930	32,618	27,321	22,880	19,566	16,286	16,091
2023	17,482	16,953	16,321	17,586	21,521	27,986	27,113	24,473	23,433	18,551	15,811	15,988
2024	17,003	17,484	15,955	17,797	20,476	22,601	28,595	21,695	21,195			


Change from Baseline:

FY	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
2020	-4.67%	-3.30%	-0.65%	-3.44%	-8.74%	0.95%	-9.88%	-13.14%	-18.86%	-15.44%	-14.14%	-12.40%
2021	-18.70%	-14.01%	-17.26%	-3.14%	-23.54%	-8.92%	-17.01%	7.87%	-17.96%	-11.39%	-3.14%	-0.37%
2022	-14.27%	-11.63%	-11.39%	-14.98%	-20.01%	-0.62%	4.61%	-9.55%	-9.38%	-1.35%	-1.95%	-3.65%
2023	-12.71%	-12.28%	-9.96%	-15.22%	-20.38%	3.27%	-13.05%	-18.97%	-7.19%	-6.46%	-4.81%	-4.26%
2024	-15.10%	-9.53%	-11.98%	-14.20%	-24.25%	-16.60%	-8.29%	-28.17%	-16.05%			

EM actively works to reduce emissions and meet University targets for carbon reduction. This chart shows monthly carbon emissions and how they have changed since the baseline year of 2019.

SUSTAINABILITY

We seek to be good stewards of our natural resources and use them wisely. This shows monthly water consumption for the Minneapolis and St Paul campuses vs the previous year.




Change from LY:



	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB
Minneapolis	8.87%	16.16%	24.96%	32.18%	-5.49%	10.19%	8.43%	17.65%	-4.05%	19.71%	5.26%	-51.17%
St Paul	1.71%	25.13%	51.90%	23.30%	-24.83%	11.06%	-20.12%	-6.57%	-38.71%	16.39%	40.42%	10.02%
Total	7.02%	18.63%	34.10%	28.67%	-11.38%	10.42%	1.52%	12.75%	-14.99%	18.89%	15.43%	-34.05%

SUSTAINABILITY

This shows total campus energy usage, separated by utility type, compared to the baseline year of 2009. It is weather-normalized to remove variations due to weather fluctuations.




SUSTAINABILITY



The University continually explores new ways to provide energy using sustainable methods. These charts show monthly electricity supplied to campus, broken out by its manner of production.

COST EFFECTIVENESS



The cheapest and most sustainable energy is that which isn't used! This chart shows the total amount of electricity supplied to campus over the past 12 months, compared to the previous year.

COST EFFECTIVENESS

Chilled Water Production Utilities by Fiscal Year

	FY18	FY19	FY20	FY21	FY22	FY23	FY24 @9 of 12
CHW PRODUCTION (TON-HRS)	53,674,555	50,462,692	53,449,008	60,759,336	62,643,652	63,124,518	42,083,272
ELECTRIC (KWH)	32,227,851	30,366,204	29,371,048	32,606,006	36,581,795	36,126,272	24,387,413
ELECTRIC (kW/Ton)	0.600	0.602	0.550	0.537	0.584	0.572	0.580
STEAM (KLB)	88,632	67,873	78,530	93,967	85,629	85,503	73,056,529
STEAM (kLb/Ton)	0.0017	0.0013	0.0015	0.0015	0.0014	0.0014	1.7360
WATER (CCF)	111,443	113,830	103,774	95,975	128,293	122,790	111,056
WATER (CCF/Ton)	0.00208	0.00226	0.00194	0.00158	0.00205	0.00195	0.00264
CHW CONSUMPTION (TON-HRS)	47,050,240	45,653,168	46,478,654	49,132,181	55,760,246	56,130,182	37,406,952
% Billed Through	87.7%	90.5%	87.0%	80.9%	89.0%	88.9%	88.9%


EM produces all of the chilled water for cooling and steam for heating the campus, as well as a sizeable portion of the electricity used. These tables show the utilities used to do this, as well as measures of the efficiency of the systems.

Twin Cities Utility Plant Production by Fiscal Year

	FY18	FY19	FY20	FY21	FY22	FY23	FY24 @9 of 12
FUEL (mmBtu)	3,423,722	3,412,151	3,125,091	3,401,086	3,525,578	3,409,177	2,598,987
STEAM OUTPUT (kLbs)	1,852,760	1,844,541	1,785,216	1,837,425	1,903,993	1,781,511	1,363,081
METERED CONSUMPTION (kLbs)	1,708,061	1,723,162	1,626,020	1,736,174	1,806,859	1,739,295	1,281,182
% BILLED THROUGH	92.2%	93.4%	91.1%	94.5%	94.9%	97.6%	94.0%
COGEN GROSS (mWh)	172,417	165,435	135,566	173,988	180,902	184,007	141,368


COST EFFECTIVENESS

Energy Management’s efforts to conserve energy are complicated by the continued growth of the University. With new buildings being erected and old ones experiencing extensive renovation, it is useful to see the trend in energy usage in concert with the increasing square footage of campus.



COST EFFECTIVENESS

This similar chart shows the ratio of campus energy usage to square footage. It shows clearly that, even though the campus is growing, Energy Management continues to find ways to reduce energy consumption.



COST EFFECTIVENESS

Rolling 12 Month Energy Use Intensity (EUI) - Top and Bottom Performing Outliers per District


District	Bldg #	Building	GSF	Actual EUI (kbtu/ft2/yr)	Expected EUI (kbtu/ft2/yr)	Actual as a Percent of Expected	Code EUI (kbtu/ft2/yr)	Actual as a Percent of Code
East Bank	191	MAST Laboratory	9,537	103	369	28%	63	164%
	003	Pattee Hall	28,991	47	163	29%	69	68%
	019	Campbell Hall	80,495	68	163	42%	79	85%
	197	Wallin Medical Biosciences	119,872	355	304	117%	230	154%
	149	Microbiology Research Facility	89,936	257	203	126%	886	29%
	049	Tate Laboratory Of Physics	260,608	161	116	139%	196	82%
Health Sciences	115	Children's Rehabilitation Center	70,851	87	196	45%	105	83%
	193	717 Delaware St SE	201,333	122	231	53%	159	77%
	143	Dwan Variety/ Masonic Cancer Research Centers	190,038	238	403	59%	238	100%
	147	Weaver-Densford Hall	195,438	212	229	93%	186	114%
	172	Weisman Art Museum	126,932	61	66	93%	117	52%
	144	Phillips-Wangensteen Building	580,141	252	237	106%	152	165%
HRA	067	Field House	89,186	20	73	27%	72	27%
	169	Recreation and Wellness Center	307,048	44	118	37%	122	36%
	181	Ridder Arena/Baseline Tennis	367,813	40	106	37%	98	41%
	182	McNamara	175,611	76	69	110%	59	128%
	052	Pioneer Hall	316,336	87	77	113%	141	62%
	126	Keeler Apartments	98,900	24	18	135%	95	25%
St Paul	432	Plant Growth Facilities-West (432)	9,244	120	330	36%	566	21%
	415	Plant Growth Facilities-West (415)	13,092	223	614	36%	172	130%
	392	Sheep Research	8,165	10	26	38%	11	89%
	411	Biological Sciences	207,115	198	139	143%	225	88%
	455	Swine Research Facility	10,559	326	85	383%	31	1,051%
	409	Veterinary Isolation Facility	31,843	367	63	580%	270	136%
West Bank	207	Willey Hall	120,464	39	132	30%	116	34%
	209	Rarig Center	173,139	76	193	40%	92	83%
	241	Regis Center for Art - East	102,035	110	260	42%	242	46%
	058	St Anthony Falls Laboratory	65,342	147	160	92%	295	50%
	201	Heller Hall	103,926	79	74	106%	84	93%
	135	Urban Research & Outreach Center	22,528	70	28	251%	100	70%

Each building has challenges to conserving energy and using our resources effectively. This table shows how much energy an individual building uses, how much we expect it to use based on the type of building it is, and how much it should use, were it built to current energy standards. We showcase six buildings per District, three that perform well, given what we expect, and three that do not.

Note 1 - Actual based on APR 23 - MAR 24 meter readings
 Note 2 - Expected based on JAN 09 - DEC 09 weather and energy data
 Note 3 - Code based on current State Energy Code

<95%	<95%
96-110%	96-110%
>110%	>110%

COST EFFECTIVENESS




MAIN ENERGY PLANT EFFICIENCY

	Apr-23	May-23	Jun-23	Jul-23	Aug-23	Sep-23	Oct-23	Nov-23	Dec-23	Jan-24	Feb-24	Mar-24
Plant Efficiency	75.8%	71.7%	72.7%	72.2%	71.5%	74.0%	73.6%	74.5%	73.5%	70.2%	71.2%	72.4%
Rolling 12 Average	72.0%	71.9%	71.9%	72.1%	72.4%	73.0%	72.9%	73.1%	73.0%	72.9%	72.7%	72.7%

It is important to run our utility plants as efficiently as possible. This chart measures how much energy on a monthly basis was brought into the Main Energy Plant, and how much flowed out, expressed as a percentage.

COST EFFECTIVENESS




SOUTHEAST PLANT EFFICIENCY

	Apr-23	May-23	Jun-23	Jul-23	Aug-23	Sep-23	Oct-23	Nov-23	Dec-23	Jan-24	Feb-24	Mar-24
Plant Efficiency	47.1%	81.7%	31.6%	0.0%	0.0%	52.7%	77.3%	70.3%	68.8%	78.8%	77.0%	76.8%
Rolling 12 Average	65.9%	67.8%	63.8%	63.8%	63.8%	57.0%	63.6%	59.1%	63.9%	64.6%	65.2%	66.2%

It is important to run our utility plants as efficiently as possible. This chart measures how much energy on a monthly basis was brought into the Southeast Steam Plant, and how much flowed out, expressed as a percentage.

COST EFFECTIVENESS




ST PAUL PLANT EFFICIENCY

	Apr-23	May-23	Jun-23	Jul-23	Aug-23	Sep-23	Oct-23	Nov-23	Dec-23	Jan-24	Feb-24	Mar-24
Plant Efficiency	77.5%	75.8%	74.9%	75.9%	75.4%	78.0%	76.9%	76.4%	73.7%	70.1%	72.7%	76.7%
Rolling 12 Average	81.7%	81.7%	81.4%	81.2%	80.8%	80.7%	80.7%	80.8%	80.0%	78.0%	76.6%	74.7%

It is important to run our utility plants as efficiently as possible. This chart measures how much energy on a monthly basis was brought into the St Paul Steam Plant, and how much flowed out, expressed as a percentage.

COST EFFECTIVENESS




MINNEAPOLIS STEAM DISTRIBUTION EFFICIENCY

	Apr-23	May-23	Jun-23	Jul-23	Aug-23	Sep-23	Oct-23	Nov-23	Dec-23	Jan-24	Feb-24	Mar-24
COND to STM Ratio	93.7%	95.5%	98.7%	99.6%	96.5%	97.7%	96.3%	93.8%	95.1%	95.3%	93.7%	92.1%
Rolling 12 Average	100.2%	100.0%	99.9%	99.7%	98.9%	98.1%	97.9%	97.3%	97.1%	96.6%	96.0%	95.3%

It is important to run our distribution systems as efficiently as possible. This chart measures how much condensate was returned vs how much steam left the Minneapolis energy plants.

COST EFFECTIVENESS



ST PAUL STEAM DISTRIBUTION EFFICIENCY

	Apr-23	May-23	Jun-23	Jul-23	Aug-23	Sep-23	Oct-23	Nov-23	Dec-23	Jan-24	Feb-24	Mar-24
COND to STM Ratio	90.9%	92.8%	91.9%	89.6%	88.5%	89.0%	54.0%	90.8%	92.1%	87.0%	90.1%	90.1%
Rolling 12 Average	90.4%	90.4%	90.4%	90.3%	90.2%	90.3%	87.8%	87.7%	88.4%	87.8%	87.7%	87.4%

It is important to run our distribution systems as efficiently as possible. This chart measures how much condensate was returned vs how much steam left the St Paul energy plant.